



Free Questions for H19-311 by certscare

Shared by Schultz on 06-06-2022

For More Free Questions and Preparation Resources

Check the Links on Last Page

Question 1

Question Type: MultipleChoice

UPS spare parts cannot be configured with Unistar SCT.

Options:

A- TRUE

B- FALSE

Answer:

B

Question 2

Question Type: MultipleChoice

Which of the following elements shall be considered when configuring a UPS? (Multiple Choice)

Options:

- A- UPS model, capacity, and parallel system mode
- B- Battery brand and capacity
- C- Brand and model of the AC and DC cables
- D- Configuration of the battery rack and battery switch box

Answer:

A, B, C, D

Question 3

Question Type: MultipleChoice

The efficiency of the UPS5000-E (25-75 kVA) power module is 96%.

Options:

- A- TRUE

B- FALSE

Answer:

B

Question 4

Question Type: MultipleChoice

By default, how many POUs are configured for one cabinet of the FusionModule2000? ()

Options:

A- 1

B- 2

C- 3

D- 4

Answer:

B

Question 5

Question Type: MultipleChoice

Do the aisles of the FusionModule800 have skylights? ()

Options:

A- Yes

B- No

Answer:

B

Question 6

Question Type: MultipleChoice

The UPS5000-E (25-125 kVA) only supports top cable routing.

Options:

A- TRUE

B- FALSE

Answer:

B

Question 7

Question Type: MultipleChoice

SCT configurator does not require permission application, allowing any user to configure at the specified URL.

Options:

A- TRUE

B- FALSE

Answer:

B

Question 8

Question Type: MultipleChoice

The number of batteries can be adjusted in the process of UPS configuration.

Options:

A- TRUE

B- FALSE

Answer:

A

Question 9

Question Type: MultipleChoice

The maximum power of the IT cabinets used by the Fusion Mod ule800 is ()

Options:

A- 3 kVA

B- 5 kVA

C- 7k VA

D- 9 kVA

Answer:

C

Question 10

Question Type: MultipleChoice

The pipe routing method for the FusionModule800 is ().

Options:

A- Top and bottom pipe routing

B- Bottom pipe routing

C- Top pipe routing

Answer:

A

Question 11

Question Type: MultipleChoice

The rated loading capacity of a 2+1 parallel system is a maximum of () times the rated loading capacity of a single UPS.

Options:

A- 3

B- 2

C- 1.6

D- 1.2

Answer:

B

Question 12

Question Type: MultipleChoice

The standard components and features in the typical configuration solution of the FusionModule500 include ().

Options:

A- Water sensor, smoke sensor, temperature and humidity sensor, and door status sensor

B- Water sensor, smoke sensor, temperature and humidity sensor, and mobile app

C- Water sensor, smoke sensor, alarm notification over short messages, and video surveillance

Answer:

A

To Get Premium Files for H19-311 Visit

<https://www.p2pexams.com/products/h19-311>

For More Free Questions Visit

<https://www.p2pexams.com/huawei/pdf/h19-311>

